

Parish Council of Coleford

Miss V Watts
Clerk to the Council
Tel: 07971 516916
Email: clerk@colefordpc.org.uk

Gallant Hill Farm
Foxcote
Radstock
BA3 5YB

GENERATOR RISK ASSESSMENT

Version	Reviewed at Coleford Parish Council meeting on:	Approved at Coleford Parish Council meeting on:
Version 1	14 th August 2024	14 th August 2024
Version 1	22 nd April 2026	22 nd April 2026

To be reviewed annually

Assessed Risk: Use of Jefferson 2.8KVA Petrol Generator		Assessed by: Vickie Watts	Date: 3 rd August 2024
SEVERITY OF HARM →	NEGLIGIBLE Superficial injuries, minor cuts and bruises	MODERATE Minor fractures or ill health leading to minor disability	SEVERE Multiple injuries, major fractures, fatalities
LIKEIHOOD OF HARM ↓			
IMPROBABLE	Slight	Tolerable	Moderate
POSSIBLE	Tolerable	Moderate	Substantial
FREQUENT	Moderate	Substantial	Intolerable

Nature of Hazard	Who might be harmed and how?	Risk	Actions already in place	Further actions required to manage this risk?	Action to be taken by whom?	Further actions by when?	Date completed
Risk of injury from generator operation	Operator and other allotment holders	Tolerable	Issue a list of authorised users who have familiarised themselves with the operation of the generator by reading the instructor manual, the data sheet for handling fuel, lifting guidelines and knows the location of the spill kit, fire extinguisher and first aid kit All authorised users to sign document confirming they have read and understood the operation manual	None	Authorised user / Full Council	Ongoing	Ongoing
Risk of poisoning from carbon monoxide fumes	Operator and other allotment holders	Slight	Ensure that the generator is only used outdoors by authorised users	None	Authorised user	Ongoing	Ongoing

Nature of Hazard	Who might be harmed and how?	Risk	Actions already in place	Further actions required to manage this risk?	Action to be taken by whom?	Further actions by when?	Date completed
Risk of receiving burns to hands or body from muffler or exhaust	Operator and other allotment holders	Tolerable	Ensure that the generator is inside the purpose-built crate during operation. Allow to cool before moving after use	None	Authorised user	Ongoing	Ongoing
Risk of electrocution or possible explosion	Operator and other allotment holders	Tolerable	Ensure that any connection to electrical equipment is only carried out by authorised user. The generator is not to be used in any wet conditions or with wet hands	None	Authorised user	Ongoing	Ongoing
Risk of fire while refuelling generator	Operator and other allotment holders	Moderate	Ensure that the generator is only refuelled when it is cold, switched off and is in flat, well-ventilated area. Check records of when it was last used. Ensure there are no naked flames present when refuelling	None	Authorised user	Ongoing	Ongoing
Risk of injury when moving generator	Operator	Tolerable	The generator should only be removed from the crate by 2 authorised users. Do not attempt if alone – Contact the parish clerk	Authorised users to review lifting guidelines	Authorised user	Ongoing	Ongoing
Risk of theft or generator	Operator	Tolerable	Generator should be padlocked to the concrete base inside the crate at all times. The lid of the crate to be padlocked at all times	None	Authorised user	Ongoing	Ongoing

Authorised Users

The following persons are over 18 years of age and authorised to use the generator providing they have familiarised themselves with:

- The operation of the generator by reading the instructions manual
- The data sheet for handling fuel
- Lifting guidelines
- The location of the spill kit, fire extinguisher and first aid kit

Please sign and date below that you agree with the terms set out above:

Name	Signature	Date

